



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5118CP0473

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Frenzelit GmbH Frankenhammer 7, D-95460 Bad Berneck
Distributor <i>Vertreiber</i>	Frenzelit GmbH Frankenhammer 7, D-95460 Bad Berneck
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing material for HTB resistant seals in the gas installation (5118)
Product Description <i>Produktbezeichnung</i>	flat sealing material on synthetic fiber basis with higher thermal resistance
Model <i>Modell</i>	novapress®850
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-00689-KP02 from 30.05.2022 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN 30653 (01.08.2018)



Date of Expiry / File No. 08.05.2027 / 22-0384-GNV
Ablaufdatum / Aktenzeichen

04.10.2022 Kir A-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
novapress®850	max. operating pressure: 1/5 bar	depending on the application

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. Registrier-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NG-5123CP0035	Flat sealing materials on synthetic fiber basis	novapress®850/novapress®85	Frenzelit GmbH

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

field of application for maximum operation pressure of 1 bar: screw connections of gas meters according to DIN 3376-1 and DIN 3376-2 as well as flange connections of gas meters according to DIN 3376-2

field of application for maximum operation pressure of 5 bar: screw connections according to DIN EN 10241 and DIN EN 10242 also flange connections according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN EN 1092-2 of pressure regulators and turning piston gas meters